(令令) DURGAPUR MUNICIPAL CORPORATION

CITY CENTRE, DURGAPUR - 713216, DIST.- PASCHIM BARDHAMAN EPABX ⇒ (0343) 2545842, 2546994, 2546107 ★ Fax No.: 254-6472

Website : durgapurmunicipalcorporation.org & E-mail : durgapurcorporation@gmail.com

Ref. No. DMC 1 W.S. 223

Date 17.06:2025

To
The Principal,
AIMS Model School,
J.P. Avenue, Zonal Centre,
Sagarbhanga,
Durgapur-713211.

From report (Copy enclosed) submitted on 02-04-2025 by the Engineers of DMC, it is found that the water supplied by DMC is safe for drinking.

This is being issued as per his application dated 26th March, 2025.

Secretary, \

Durgapur Municipal Corporațion

PRINCIPAL

AIMS MODEL SCHOOL AFFILIATION NO.: 2430385
UP AVENUE, ZONAL CENTRE

SAGANDIANGA, DURGAPUR-713211

MANAGER
AIMS MODEL SCHOOL
AIMS MODEL SCHOOL
AFFILIATION NO.: 2430385
AF

DURGAPUR MUNICIPAL CORPORATION

PHYSICAL, CHEMICAL AND BACTERIOLOGICAL WATER TEST REPORT

Sample Name:-

:- Drinking water. AIMS MODEL SCHOOL, Sagarbhanga, Durgapur.

Date of Sampling: 02/04/25

Sl. No	Parameters	Unit	Recommended Drinking Water Quality as per IS:: 10500:2012		Result
			Desirable Limit	Permissible Limit	
1	Temperature	Deg. C	was grade and	Parker Marker St.	36.0
2	Turbidity	NTU	1	5	0.80
3	Colour	Hazen	5	15	2.01
4	IMP PH		6.5-8.5	6.5-8.5	8.09
, 5	Total Hardness as CaCO3	Mg/Lit	200	600	156
6	Calcium Hardness	Mg/ut			84
7	Alkalinity	Mg/lit	200	600	110
8	Residual Chiorine Min.	Mallit	0.2	1	0.20
9	Chloride	Malut	250	1000	22.03
10	Feçal Coliform	MPN/100 ml	Absent	Absent	Absent
11	Total Coliform	MBN/100 mg	Absent	Absent	Absent

Water in safe for drinking